



Estimation of Hammerstein nonlinear systems with noises using filtering and recursive approaches for industrial control*

Mingguang ZHANG¹, Feng LI^{†‡1}, Yang YU¹, Qingfeng CAO²

¹School of Electrical & Information Engineering, Jiangsu University of Technology, Changzhou 213001, China

²College of Electrical, Energy and Power Engineering, Yangzhou University, Yangzhou 225127, China

[†]E-mail: lifeng@jst.edu.cn

Received Sept. 13, 2023; Revision accepted Dec. 3, 2023; Crosschecked Dec. 20, 2023; Published online Dec. 29, 2023

Abstract: This paper discusses a strategy for estimating Hammerstein nonlinear systems in the presence of measurement noises for industrial control by applying filtering and recursive approaches. The proposed Hammerstein nonlinear systems are made up of a neural fuzzy network (NFN) and a linear state–space model. The estimation of parameters for Hammerstein systems can be achieved by employing hybrid signals, which consist of step signals and random signals. First, based on the characteristic that step signals do not excite static nonlinear systems, that is, the intermediate variable of the Hammerstein system is a step signal with different amplitudes from the input, the unknown intermediate variables can be replaced by inputs, solving the problem of unmeasurable intermediate variable information. In the presence of step signals, the parameters of the state–space model are estimated using the recursive extended least squares (RELS) algorithm. Moreover, to effectively deal with the interference of measurement noises, a data filtering technique is introduced, and the filtering-based RELS is formulated for estimating the NFN by employing random signals. Finally, according to the structure of the Hammerstein system, the control system is designed by eliminating the nonlinear block so that the generated system is approximately equivalent to a linear system, and it can then be easily controlled by applying a linear controller. The effectiveness and feasibility of the developed identification and control strategy are demonstrated using two industrial simulation cases.

Key words: Hammerstein nonlinear systems; Neural fuzzy network; Data filtering; Hybrid signals; Industrial control
<https://doi.org/10.1631/FITEE.2300620>

CLC number: TP273

1 Introduction

Recently, the accelerated advancements in the domains of computing, communication, and control have brought about substantial transformations in human society. In the context of Industry 4.0 and intelligent manufacturing, industrial cyber-physical systems

(ICPSs) are thriving due to their unique advantages. ICPSs concentrate on the seamless integration and synchronization of computing resources with physical resources, primarily applied in various intelligent systems such as robotics (Huang J et al., 2022), smart grid (Wen et al., 2021; Ning et al., 2023), and smart transportation (Ge et al., 2022, 2023; Xie et al., 2023; Zhang XM et al., 2023). If effective optimization control strategies cannot be formulated, the control strategy will inevitably affect the smooth operation of ICPS and even reduce the safety of the systems (Zhang H et al., 2018). Within the realm of control systems, almost all systems have certain nonlinear characteristics (Wang YJ and Yang, 2021). Amid the relentless advancement of contemporary technology,

[‡] Corresponding author

* Project supported by the National Natural Science Foundation of China (No. 62003151), the Changzhou Science and Technology Bureau, China (No. CJ20220065), the Qinglan Project of Jiangsu Province, China (No. 2022[29]), and the Zhongwu Youth Innovative Talents Support Program of Jiangsu University of Technology, China (No. 202102003)

ORCID: Mingguang ZHANG, <https://orcid.org/0009-0005-0205-6563>; Feng LI, <https://orcid.org/0000-0001-9445-1627>

© Zhejiang University Press 2023

the nonlinearity and complexity of control objects continue to increase, and many advanced control methods require mathematical models of nonlinear systems (Xu et al., 2015; Xu, 2016; Zhang HY et al., 2021).

Hammerstein systems are typical block-oriented models, the basic structure of which is a static nonlinear block connected to a dynamic linear block (Hou et al., 2023; Janjanam et al., 2023; Zhao et al., 2023). It has a simple structure and can describe various typical nonlinear processes, such as the heating process (Hammar et al., 2019), the pH process (Li et al., 2023b), and the process of a continuous stirred tank reactor (Li et al., 2023a). Lately, some substantial estimation approaches have been proposed for the Hammerstein systems. These approaches can be broadly bifurcated into two classes—those that directly calculate each indeterminate parameter within the Hammerstein systems (Filipovic, 2019; Ma JX et al., 2020; Wang DQ et al., 2020) and those that independently estimate each block parameter of Hammerstein systems by reconstructing the internal unmeasured variable (Chen and Chen, 2011; Kothari et al., 2020; Li et al., 2023c).

Noise generally exists in practical applications, and the noise in actual industrial processes is rarely white noise that conforms to a normal distribution. Consequently, exploring estimates of Hammerstein systems under the influence of noise interference becomes paramount. Data filtering is usually used to get rid of the outliers and weaken the influence of noise in linear and nonlinear systems, and has been applied to identify model parameters (Wang DQ et al., 2013; Ding et al., 2015; Ma JX et al., 2016; Ji et al., 2021; Shi et al., 2023). The principle of data filtering is to filter the input–output data of a system using a linear filter; it should be emphasized that this technique can change only the influence of output noises on the system but cannot change the structure of the system itself. To solve the multiple-input single-output Hammerstein identification problem in the presence of autoregressive noises, Ji et al. (2021) introduced the multiple-stage Levenberg–Marquardt method based on the data filtering technique and the hierarchical identification principle, which can decrease the influence of noise on parameter estimation. The investigation of Wang DQ et al. (2013) focused on a fresh parameter estimation method for Hammerstein systems with

output noises, using a recursive least squares (RLS) algorithm with a key-term separation principle and data filtering technique. To enhance the convergence rate and the precision of parameter identification, a forgetting factor stochastic gradient method based on filtering technology was proposed by Ma JX et al. (2016). We would like to point out that the approach capability of the static nonlinear block by way of polynomial modeling or a piecewise function is limited for nonlinear discontinuous functions in Wang DQ et al. (2013), Ma JX et al. (2016), and Ji et al. (2021). To alleviate the issues mentioned above, neural networks (Michalkiewicz, 2012; Cui et al., 2014) and fuzzy logic systems (Khalifa et al., 2021) have been extensively used in modeling nonlinear dynamic systems due to their adeptness at capturing nonlinearity with remarkable accuracy. Cui et al. (2014) used a function link artificial neural network to model a static nonlinear function, and independently determined parameters of linear and nonlinear blocks by employing the least squares method and the Levenberg–Marquardt algorithm, respectively. Khalifa et al. (2021) introduced the autoregressive moving average and fuzzy systems, and then an identification method based on the Lyapunov function was applied for Hammerstein systems. While neural network models exhibit robust self-learning capacities, they fall short of emulating the reasoning abilities intrinsic to the human brain. Unlike neural network models, fuzzy systems lack self-learning capabilities and there are certain limitations to their practical implementation. As a result, a significant technique is to apply a neural fuzzy network (NFN) model that combines the fuzzy reasoning ability of a fuzzy system and the self-learning of neural network models as the static nonlinear block in Hammerstein systems. It is essential to recognize that the identification process for the NFN-based Hammerstein systems diverges significantly from that of a standalone NFN model. The primary distinction stems from the structural constraints dictated by the Hammerstein systems. Clearly, the identification challenge that arises demands the concurrent consideration of nonlinear mapping and linear dynamics. Conversely, research on individual NFNs primarily centers on the identification of a singular, global nonlinear mapping.

Motivated by the aforementioned methods, a methodology for estimating neural fuzzy Hammerstein

nonlinear systems using data filtering technology and a recursive approach is developed in this study. Practical application processes are often disturbed by random measurement noises, and thus it is extremely significant to consider the NFN-based Hammerstein systems with measurement noises. The parameter estimate scheme presented can be delineated in the subsequent two steps. In the first step, a nonlinear block and a linear block are separated by using the characteristic that step signals are unable to activate nonlinear blocks, which avoids decomposing parameter product terms in a synchronous estimate and improves the estimation accuracy. Using input and output data derived from step signals, the parameters of the dynamic linear block are determined through the recursive extended least squares (RELS) approach. In the second step, based on input–output random signals, the cluster method is used to calculate the center and width of the NFN model. Concurrently, the weight of the NFN model is updated by employing the data-filtering-based RELS technique.

The notable innovations of this study are evident in the following aspects:

1. A novel NFN-based Hammerstein system is proposed by combining the advantages of the structure of Hammerstein systems and NFNs, and the modeling accuracy is improved compared with that of a single NFN or neural network (Cui et al., 2014).

2. Unlike synchronous estimation schemes (Hammar et al., 2019; Li et al., 2023b; Zhao et al., 2023), which contain the parameters' product terms of the linear and nonlinear blocks, the strategy presented here decouples the parameter estimation of the nonlinear block from that of the linear block using designed

hybrid signals, resulting in an enhancement of the estimation accuracy of the systems.

3. Data filtering is introduced to derive a filtering-based RELS algorithm for the Hammerstein nonlinear systems with noises, which can reduce the impact of moving average noise and improve the precision of parameter estimation.

2 System model and problem formulation

The Hammerstein systems with measurement noises (Ding et al., 2015; Li et al., 2023b), shown in Fig. 1, are nonlinear systems defined by a sequential configuration of a static nonlinear block preceding a dynamic linear block.

The input–output relationships can be described as follows:

$$v(t) = f(u(t)), \quad (1)$$

$$x(t+1) = Ax(t) + bv(t), \quad (2)$$

$$g(t) = cx(t), \quad (3)$$

$$r(t) = D(z)e(t), \quad (4)$$

$$y(t) = g(t) + r(t), \quad (5)$$

where the system input and output are described as $u(t)$ and $y(t)$, respectively, $v(t)$ is the output of the static nonlinear block, $g(t)$ is the output of the linear block, $r(t)$ indicates colored noises, and $e(t)$ represents Gaussian noises. $D(z) = 1 + d_1z^{-1} + d_2z^{-2} + \dots + d_nz^{-n}$ is a linear combination of backward operators z^{-1} . The state space model is represented by Eqs. (2) and (3). $x(t) = [x_1(t), x_2(t), \dots, x_n(t)]^T$ is the state vector. A , b , and c are the system parameter matrix or




Fig. 1 Hammerstein nonlinear systems

vectors. $b=[b_1, b_2, \dots, b_n]^T \in \mathbb{R}^{n \times 1}$, $c=[1, 0, \dots, 0] \in \mathbb{R}^{1 \times n}$, and

$$A = \begin{bmatrix} 0 & 1 & 0 & \dots & 0 \\ 0 & 0 & 1 & \dots & \vdots \\ \vdots & \vdots & & & 0 \\ 0 & 0 & \dots & 0 & 1 \\ -a_n & -a_{n-1} & -a_{n-2} & \dots & -a_1 \end{bmatrix} \in \mathbb{R}^{n \times n}.$$

In this paper, the nonlinear block is approximated using the NFN (Li et al., 2023b), as illustrated in Fig. 1. Based on Fig. 1, the NFN can be described as follows:

$$\hat{v}(t) = \hat{f}(u(t)) = \sum_{i=1}^L \phi_i(u(t)) w_i, \quad (6)$$

$$\phi_i(u(t)) = \frac{\mu_i(u(t))}{\sum_{i=1}^L \mu_i(u(t))}, \quad (7)$$

$$\mu_i(u(t)) = \exp\left(-\frac{(u(t) - c_i)^2}{\sigma_i^2}\right), \quad (8)$$

where $\hat{f}(\cdot)$ represents the estimation of the NFN, the center and width are denoted as c_i and σ_i , respectively, w_i represents the weights, and L indicates the total count of fuzzy rules.

Defining ε as a constant threshold, the objective of the proposed parameter identification technique is to ascertain the indeterminate parameters of both static nonlinear and dynamical linear blocks. These parameters must meet the subsequent criteria:

$$\begin{aligned} E(\hat{f}, \hat{g}, \hat{D}) &= \frac{1}{2N} \sum_{t=1}^N [y(t) - \hat{y}(t)]^2 \leq \varepsilon \\ \text{s.t. } \hat{v}(t) &= \hat{f}(u(t)), \\ \hat{y}(t) &= \hat{g}(t) + \hat{D}(z)\hat{e}(t), \end{aligned} \quad (9)$$

where $\hat{y}(t)$ is the estimate of Hammerstein systems and N is the data length.

3 Parameter estimate of Hammerstein systems

We delineate the identification procedure for NFN-based Hammerstein systems in this section. The existing research indicates that hybrid signals, comprising step and random signals, can achieve two-stage identification of the Hammerstein systems inte-

grated with the state-space model and the NFN model. Initially, the step response aids in the parameter estimate of the state-space model. Subsequently, the random input response is employed to compute the NFN parameters.

Kothari et al. (2020) elucidated that, with a step signal input to the Hammerstein systems, the nonlinear block becomes operational, leading to an amplitude variation for the consistent input. To specify, when the step input traverses a static nonlinear system, the resultant output is step signals, albeit with varying amplitudes, as illustrated in Fig. 2. Consequently, the intermediate variable is $v(t) = \beta u(t)$. Hence, with the introduction of a step input, each block in the Hammerstein systems can be discerned autonomously.




Fig. 2 Relationship between u and v under step signals

3.1 Estimate of the dynamic linear block

When a step signal $u_i(t)$ is used to identify parameters of the linear block, based on Eq. (2), we obtain

$$x_i(t+1) = x_{i+1}(t) + b_i v(t), \quad i = 1, 2, \dots, n-1, \quad (10)$$

$$\begin{aligned} x_n(t+1) &= -a_n x(t) - a_{n-1} x(t) - \dots \\ &\quad - a_1 x(t) + b_n v(t). \end{aligned} \quad (11)$$

By multiplying z^{-i} and z^{-n} on both sides of Eqs. (10) and (11) separately, we have

$$\begin{cases} x_1(t) = x_2(t-1) + b_1 v(t-1), \\ x_2(t-1) = x_3(t-2) + b_2 v(t-2), \\ \vdots \\ x_{n-1}(t-n+2) = x_n(t-n+1) + b_{n-1} v(t-n+1), \\ x_n(t-n+1) = -a_n x_1(t-n) - a_{n-1} x_2(t-n) - \dots \\ \quad - a_1 x_n(t-n) + b_n v(t-n). \end{cases} \quad (12)$$

Simplifying Eq. (12), we obtain

$$x_1(t) = - \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) + \sum_{j=1}^{n_b} b_j v(t-j). \quad (13)$$

Because of the relationship between u and v under step signals, replacing $v(t)$ with $\beta u_1(t)$, we have

$$x_1(t) = - \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) + \sum_{j=1}^{n_b} \bar{b}_j u_1(t-j), \quad (14)$$

where $\bar{b}_j = \beta b_j$.

According to Eqs. (3) and (14), we can derive

$$g(t) = x_1(t) = - \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) + \sum_{j=1}^{n_b} \bar{b}_j u_1(t-j). \quad (15)$$

Based on Eqs. (4), (5), and (15), the output $y_1(t)$ can be written as

$$y_1(t) = - \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) + \sum_{j=1}^{n_b} \bar{b}_j u_1(t-j) + \sum_{m=1}^{n_d} d_m e(t-m) + e(t). \quad (16)$$

Moreover, the output $y_1(t)$ can be simplified as

$$y_1(t) = \psi_1^T(t) \theta_1 + e(t), \quad (17)$$

where $\psi_1(t) = [\phi_1(t), e(t-1), e(t-2), \dots, e(t-n_d)]^T$, $\theta_1 = [a_1, a_2, \dots, a_{n_a}, \beta b_1, \beta b_2, \dots, \beta b_{n_b}, d_1, d_2, \dots, d_{n_d}]^T$, $\phi_1(t) = [-x_{n_a}(t-n_a), -x_{n_a-1}(t-n_a), \dots, -x_1(t-n_a), u_1(t-1), u_1(t-2), \dots, u_1(t-n_b)]^T$.

However, $x(t)$ and $e(t)$ are unidentified variables; a viable approach entails the utilization of estimations $\hat{x}(t)$ and $\hat{e}(t)$ as substitutes for the unidentified variables, and thus we have

$$\hat{y}_1(t) = \hat{\psi}_1^T(t) \hat{\theta}_1 + \hat{e}(t), \quad (18)$$

where $\hat{\psi}_1(t) = [\hat{\phi}_1(t), \hat{e}(t-1), \hat{e}(t-2), \dots, \hat{e}(t-n_d)]^T$, $\hat{\phi}_1(t) = [-\hat{x}_{n_a}(t-n_a), -\hat{x}_{n_a-1}(t-n_a), \dots, -\hat{x}_1(t-n_a), u_1(t-1), u_1(t-2), \dots, u_1(t-n_b)]^T$.

Define and minimize the mean square criterion functions:

$$J(\hat{\theta}_1) = \sum_{t=1}^N \|y_1(t) - \hat{\psi}_1^T(t) \hat{\theta}_1\|^2. \quad (19)$$

The identification of parameter θ_1 is achieved using the RELS method as follows:

$$\hat{\theta}_1(t) = \hat{\theta}_1(t-1) + L(t) [y_1(t) - \hat{\psi}_1^T(t) \hat{\theta}_1(t-1)], \quad (20)$$

$$L(t) = P(t-1) \hat{\psi}_1^T(t) [1 + \hat{\psi}_1^T(t) P(t-1) \hat{\psi}_1(t)]^{-1}, \quad (21)$$

$$P(t) = [I_{2n} - L(t) \hat{\psi}_1^T(t)] P(t-1), \quad (22)$$

$$\hat{e}(t) = y_1(t) - \hat{\psi}_1^T(t) \hat{\theta}_1(t-1), \quad (23)$$

$$\hat{x}(t+1) = \hat{A}(t) \hat{x}(t) + \hat{b}(t) u_1(t). \quad (24)$$

Thus, the parameters pertaining to the linear block are determined.

3.2 Estimate of the static nonlinear block

According to the previous analysis, the parameters \hat{a}_i and \hat{b}_j have been identified. In this subsection, a group of random signals $u_2(t)$ and output $y_2(t)$ is applied to nonlinear element estimation. The center c_l and width σ_l of NFN can be acquired by a cluster algorithm (Li et al., 2022), which is expressed by

$$c_l = c_l + \frac{\lambda}{N_L + 1} (u_2(t) - c_l), \quad (25)$$

$$\sigma_l = \min_{\substack{j=1,2,\dots,N_L \\ j \neq l}} \frac{|c_i - c_j|}{\rho}, \quad (26)$$

where N_L is the number of clusters belonging to L , $\lambda \in [0, 1]$ is an adjustable parameter, and $\rho \in [1, 2]$ denotes an overlapping parameter.

After that, the primary challenge lies in identifying the weight coefficients w_l .

According to Fig. 1, we can obtain a noise variable

$$r(t) = D(z)e(t) = \varphi_c^T(t) \theta_c + e(t), \quad (27)$$

where $\varphi_c(t) = [e(t-1), e(t-2), \dots, e(t-n_d)]^T$ and $\theta_c = [d_1, d_2, \dots, d_{n_d}]^T$.

Based on Eqs. (5) and (27), we obtain

$$\begin{aligned} y_2(t) &= g(t) + r(t) \\ &= \varphi_s^T(t) \theta_s + \varphi_c^T(t) \theta_c + e(t) \\ &= \psi_2^T(t) \theta_2 + e(t), \end{aligned} \quad (28)$$

where $\psi_2(t)=[\varphi_s(t), \varphi_e(t)]^T$, $\theta_s=[a_1, a_2, \dots, a_{n_a}, b_1 w_1, b_1 w_2, \dots, b_1 w_L, b_2 w_1, b_2 w_2, \dots, b_2 w_L, \dots, b_{n_b} w_1, b_{n_b} w_2, \dots, b_{n_b} w_L]^T$, $\theta_2=[\theta_s, \theta_e]^T$, $\varphi_s(t)=[-x_{n_a-i+1}(t-n_a), -x_{n_a-i}(t-n_a), \dots, -x_1(t-n_a), \phi_1(u_2(t-1)), \phi_2(u_2(t-1)), \dots, \phi_L(u_2(t-1)), \phi_1(u_2(t-2)), \phi_2(u_2(t-2)), \dots, \phi_L(u_2(t-2)), \dots, \phi_1(u_2(t-n_b)), \phi_2(u_2(t-n_b)), \dots, \phi_L(u_2(t-n_b))]^T$.

To enhance identification precision, a linear filter $1/D(z)$ is employed to Hammerstein systems. It should be emphasized that the filter can change only the influence of colored noises on the system but cannot change the structure of the system itself. Based on the constant input-output relation, the structure of the systems is simplified, which can simplify calculations and improve parameter estimation accuracy (Ma L and Liu, 2016).

Multiplying both sides of Eq. (28) by $1/D(z)$, we obtain

$$\begin{aligned} \frac{1}{D(z)} y_2(t) &= \frac{1}{D(z)} g(t) + e(t) \\ &= \frac{1}{D(z)} \left(- \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) \right. \\ &\quad \left. + \sum_{j=1}^{n_b} b_j v(t-j) \right) + e(t). \end{aligned} \quad (29)$$

Define the filtered output $y_f(t)$, filtered internal variable $g_f(t)$, and filtered input $v_f(t)$ as

$$y_f(t) = \frac{1}{D(z)} y_2(t) = y_2(t) - \sum_{i=1}^{n_a} d_i y_f(t-i), \quad (30)$$

$$\begin{aligned} g_f(t) &= \frac{1}{D(z)} g(t) = \frac{1}{D(z)} x_1(t) \\ &= \frac{1}{D(z)} \left(- \sum_{i=1}^{n_a} a_i x_{n-i+1}(t-n_a) \right. \\ &\quad \left. + \sum_{j=1}^{n_b} b_j v(t-j) \right), \end{aligned} \quad (31)$$

$$x_{if}(t) = \frac{1}{D(z)} x_i(t) = x_i(t) - \sum_{i=1}^{n_a} d_i x_{if}(t-i), \quad (32)$$

$$v_f(t) = \frac{1}{D(z)} v(t) = \sum_{i=1}^L w_i U_i(t), \quad (33)$$

where $U_i(t) = \frac{1}{D(z)} \phi_i(u_2(t))$.

Thus, we can obtain

$$\begin{aligned} y_f(t) &= g_f(t) + e(t) \\ &= - \sum_{i=1}^{n_a} a_i x_{n-i+1f}(t-n_a) \\ &\quad + \sum_{j=1}^{n_b} \sum_{l=1}^L b_j w_l U_l(t-j) + e(t). \end{aligned} \quad (34)$$

According to Eq. (34), we have

$$y_f(t) = \varphi_f^T(t) \theta_s + e(t), \quad (35)$$

where $\varphi_f(t)=[-x_{n_a-i+1f}(t-n_a), -x_{n_a-if}(t-n_a), \dots, -x_{1f}(t-n_a), U_1(t-1), U_2(t-1), \dots, U_L(t-1), U_1(t-2), U_2(t-2), \dots, U_L(t-2), \dots, U_1(t-n_b), U_2(t-n_b), \dots, U_L(t-n_b)]^T$.

Note that Eq. (35) contains unknown variables $y_f(t)$ and $\varphi_f(t)$, and thus the identification algorithm can not be implemented. To circumvent this limitation, a viable approach entails the utilization of estimation residuals as substitutes for the unidentified variables at time t .

Define the parameter estimation of the noises model as

$$\hat{\theta}_e(t) = [\hat{d}_1(t), \hat{d}_2(t), \dots, \hat{d}_{n_d}(t)]^T. \quad (36)$$

Thus, the estimation of $D(z)$ is expressed as

$$\hat{D}(z) = 1 + \hat{d}_1(t)z^{-1} + \hat{d}_2(t)z^{-2} + \dots + \hat{d}_{n_d}(t)z^{-n_d}. \quad (37)$$

Furthermore, we have

$$\hat{v}_f(t) = \sum_{i=1}^L w_i \hat{U}_i(t), \quad (38)$$

$$\begin{aligned} \hat{U}_i(t) &= \frac{1}{\hat{D}(z)} \phi_i(u_2(t)) \\ &= - \sum_{i=1}^{n_d} \hat{d}_i(t) \hat{U}_i(t-i) + \phi_i(u_2(t)), \end{aligned} \quad (39)$$

$$\hat{y}_f(t) = \frac{1}{\hat{D}(z)} y_2(t) = y_2(t) - \sum_{i=1}^{n_d} \hat{d}_i \hat{y}_f(t-i), \quad (40)$$

$$\hat{x}_{if}(t) = \frac{1}{\hat{D}(z)} \hat{x}_i(t) = \hat{x}_i(t) - \sum_{i=1}^{n_d} \hat{d}_i \hat{x}_{if}(t-i), \quad (41)$$

$$\hat{x}(t+1) = \hat{A}(t)\hat{x}(t) + \hat{b}(t)\hat{v}(t). \quad (42)$$

So, the estimate of $r(t)$ is

$$\hat{r}(t) = y_2(t) - \hat{\phi}_s^T(t)\hat{\theta}_s(t). \quad (43)$$

By defining and minimizing the mean square criterion functions $J(\hat{\theta}_s) = \sum_{t=1}^N \|\hat{y}_f(t) - \hat{\phi}_f^T(t)\hat{\theta}_s\|^2$ and $J(\hat{\theta}_e) = \sum_{t=1}^N \|\hat{r}(t) - \hat{\phi}_e^T(t)\hat{\theta}_e\|^2$, the data-filtering-based RELS approach can be obtained:

$$\hat{\theta}_s(t) = \hat{\theta}_s(t-1) + L_s(t) [\hat{y}_f(t) - \hat{\phi}_f^T(t)\hat{\theta}_s(t-1)], \quad (44)$$

$$L_f(t) = \frac{P_f(t-1)\hat{\phi}_f(t)}{1 + \hat{\phi}_f^T(t)P_f(t-1)\hat{\phi}_f(t)}, \quad (45)$$

$$P_f(t) = [I - L_f(t)\hat{\phi}_f(t)]P_f(t-1), \quad (46)$$

$$\hat{\phi}_f(t) = [-\hat{x}_{n_a-i+1f}(t-n_a), -\hat{x}_{n_a-1f}(t-n_a), \dots, -\hat{x}_{1f}(t-n_a), \hat{U}_1(t-1), \hat{U}_2(t-1), \dots, \hat{U}_L(t-1), \hat{U}_1(t-2), \hat{U}_2(t-2), \dots, \hat{U}_L(t-2), \dots, \hat{U}_1(t-n_b), \hat{U}_2(t-n_b), \dots, \hat{U}_L(t-n_b)]^T, \quad (47)$$

$$\hat{y}_f(t) = y_2(t) - \sum_{i=1}^{n_d} \hat{d}_i \hat{y}_f(t-i), \quad (48)$$

$$\hat{U}_l(t) = -\sum_{i=1}^{n_d} \hat{d}_i(t)\hat{U}_l(t-i) + \phi_l(u_2(t)), \quad (49)$$

$$\hat{x}_{if}(t) = \hat{x}_i(t) - \sum_{i=1}^{n_d} \hat{d}_i \hat{x}_{if}(t-i), \quad (50)$$

$$\hat{x}(t+1) = \hat{A}(t)\hat{x}(t) + \hat{b}(t)\hat{v}(t), \quad (51)$$

and

$$\hat{\theta}_e(t) = \hat{\theta}_e(t-1) + L_e(t) [\hat{r}(t) - \hat{\phi}_e^T(t)\hat{\theta}_e(t-1)], \quad (52)$$

$$L_e(t) = \frac{P_e(t-1)\hat{\phi}_e(t)}{1 + \hat{\phi}_e^T(t)P_e(t-1)\hat{\phi}_e(t)}, \quad (53)$$

$$P_e(t) = [I - L_e(t)\hat{\phi}_e(t)]P_e(t-1), \quad (54)$$

$$\hat{\theta}_e(t) = [-\hat{x}_{n_a-i+1}(t-n_a), -\hat{x}_{n_a-i}(t-n_a), \dots, -\hat{x}_1(t-n_a), \phi_1(u_2(t-1)), \phi_2(u_2(t-1)), \dots, \phi_L(u_2(t-1)), \phi_1(u_2(t-2)), \phi_2(u_2(t-2)), \dots, \phi_L(u_2(t-2)), \dots, \phi_1(u_2(t-n_b)), \phi_2(u_2(t-n_b)), \dots, \phi_L(u_2(t-n_b))]^T, \quad (55)$$

$$\hat{\phi}_e(t) = [\hat{e}_f(t-1), \hat{e}_f(t-2), \dots, \hat{e}_f(t-n_d)]^T, \quad (56)$$

$$\hat{r}(t) = y_2(t) - \hat{\phi}_s^T(t)\hat{\theta}_s(t), \quad (57)$$

$$\hat{e}_f(t) = \hat{y}_f(t) - \hat{\phi}_f^T(t)\hat{\theta}_s(t), \quad (58)$$

$$\hat{\theta}_s = [\hat{a}_1, \hat{a}_2, \dots, \hat{a}_{n_a}, \hat{b}_1\hat{w}_1, \hat{b}_1\hat{w}_2, \dots, \hat{b}_1\hat{w}_L, \hat{b}_2\hat{w}_1, \hat{b}_2\hat{w}_2, \dots, \hat{b}_2\hat{w}_L, \dots, \hat{b}_{n_b}\hat{w}_1, \hat{b}_{n_b}\hat{w}_2, \dots, \hat{b}_{n_b}\hat{w}_L]^T, \quad (59)$$

To provide a clearer description of the proposed method, the detailed estimate procedure is illustrated in Fig. 3.




Fig. 3 Flowchart of the developed parameter identification method

4 Simulation and analysis

To corroborate the efficacy and precision of the proposed parameter estimation method, two typical

nonlinear processes, namely the pH nonlinear process and the continuous stirred tank reactor (CSTR), are simulated in this section.

4.1 pH neutralization process control

In the actual chemical production process, the control of pH value is often involved, and its control effect will seriously affect the purity of the substance. To corroborate the efficacy of the proposed strategy, we conduct a simulation using the pH neutralization process in chemical production (Smith et al., 2007). Fig. 4 presents a diagram of the pH neutralization process. Alkaline solution uses caustic soda (NaOH), while acidic solution uses hydrochloric acid (HCl). The pH value of the neutralization tank is regulated by adjusting the flow rate of HCl.




Fig. 4 Process of pH neutralization

The pH model can be expressed as

$$\begin{aligned}
 F_{\text{out}} &= F_{\text{HCl}} + F_{\text{NaOH}}, \\
 V \frac{dX_{\text{HCl}}}{dt} &= F_{\text{HCl}} C_{0\text{HCl}} - F_{\text{out}} X_{\text{HCl}}, \\
 V \frac{dX_{\text{NaOH}}}{dt} &= F_{\text{NaOH}} C_{0\text{NaOH}} - F_{\text{out}} X_{\text{NaOH}}, \\
 \frac{dQ}{dt} &= \frac{1}{V} (F_{\text{HCl}} X_{\text{HCl}} - F_{\text{NaOH}} X_{\text{NaOH}} - (F_{\text{HCl}} + F_{\text{NaOH}}) Q), \\
 Q &= 10^{-\text{pH}} - \frac{K_{\text{W}}}{10^{-\text{pH}}}.
 \end{aligned}$$

Table 1 gives the nominal values of the parameters.

To handle the developed identification scheme, hybrid signals, including step signals with an amplitude of 0.5 and random signals with the amplitude distribution in $[-0.5, 0.5]$, are employed to acquire the process input–output. Applying step signals to input–output, the linear dynamic block can be

Table 1 Nominal values

Parameter	Parameter implication	Value
V	Volume	2 L
X_{HCl}	HCl concentration	0.001 mol/L
X_{NaOH}	NaOH concentration	0.001 mol/L
X_{A}	HCl flow	0.0067 L/s
X_{B}	NaOH flow	0.005 L/s
K_{W}	Fixed value	10^{-14}
$C_{0\text{HCl}}$	HCl initial concentration	0.01 mol/L
$C_{0\text{NaOH}}$	NaOH initial concentration	0.1 mol/L

obtained by $\hat{y}(t) = 1.0341x_2(t-2) - 0.1868x_1(t-2) + 0.1899\hat{v}(t-1) + 0.1899\hat{v}(t-2)$. Then, we set the parameters as $\rho=1.0$ and $\lambda=0.01$, and obtain an identified NFN-based Hammerstein system.

The Hammerstein model serves as a structural framework for representing a nonlinear system by segregating the static nonlinear component from the dynamic linear component. Consequently, we can initially employ the identified linear parameters to estimate the intermediate variables associated with the dynamic linear portion. Subsequently, we proceed to construct the inverse model for the static nonlinear section, using both the input and the estimated intermediate variables. This approach results in an apparent linear relationship between the system's input and output. Hence, we can effectively transform the nonlinear control problem into a linear control problem. Fig. 5 illustrates the control architecture based on the identified Hammerstein system.

For comparison, a traditional proportional-integral (PI) controller characterized by $u(t)=u(t-1) + K[e(t) - e(t-1) + e(t)/\tau]$, a control-based Hammerstein system using a data-filtering-based forgetting factor stochastic gradient identification algorithm (Control-H-F-FFSG) in Ma JX et al. (2016), and MPC control of the Hammerstein system (MPC-H) (Du et al., 2018) are used to control the pH process, where $e(t) = y_r(t) - y(t)$, and y_r is the reference trajectory. Within this study, the controller parameters of the proposed method are $K=0.6$ and $\tau=70$, and the sampling time and prediction step size of the MPC controller are set to 0.02 s and 5, respectively. The pH control results with different values using different methods are shown in Fig. 6.

As can be easily seen in Fig. 6, the proposed control system using an estimated NFN-Hammerstein




Fig. 5 pH process control system




Fig. 6 Set value tracking output response

system manifests a superior control performance in contrast to the traditional PI controller, the MPC-H method, and the Control-H-F-FFSG method. In general, for selecting different pH values, the presented control method can track, with effect, the set values with better overshoot and a higher response speed. To be specific, when the pH value is 8, the overshoot of the proposed control method is reduced compared to the traditional PI controller, the MPC-H method, and the Control-H-F-FFSG method. Thus, the developed NFN-Hammerstein system provides a feasible scheme for the design of the control system.

4.2 CSTR control

Due to the strong nonlinearity of the production process of the chemical CSTR systems, traditional linear control cannot meet the standards required for industrial production efficiency. Therefore, for the control of CSTR systems, it is necessary to switch ideas and adopt control methods that are more suitable for nonlinear system control, thus improving the control efficiency and economic benefits of the CSTR system’s chemical production process. In this example, we consider a CSTR process (Jia et al., 2005), and its dynamic characteristics are as follows:

$$\frac{dC_A}{dt} = -k_1 C_A - k_3 C_A^2 + \frac{F}{V} (C_{Af} - C_A),$$

$$\frac{dC_B}{dt} = k_1 C_A - k_2 C_B + \frac{F}{V} C_B,$$

$$y = C_B.$$

Table 2 lists the kinetic parameters.

Table 2 Kinetic parameters

Variable	Parameter implication	Value
k_1	Kinetic parameter	50 h^{-1}
k_2	Kinetic parameter	100 h^{-1}
k_3	Kinetic parameter	$10 \text{ L}/(\text{mol}\cdot\text{h})$
C_{A0}	A initial concentration	3.0 mol/L
C_{B0}	B initial concentration	1.12 mol/L
V	Volume	1 L
F	Flow rate	34.3 L/h
C_{Af}	Feed concentration	10 mol/L

We use step signals and random signals, as illustrated in Fig. 7, to obtain the input–output data for the CSTR, and the data are normalized. Based on the step signals, the expression of the linear block can be




Fig. 7 Input–output data of CSTR

obtained by $\hat{y}(t)=0.2277x_2(t-2)-0.1339x_1(t-2)-0.0326\hat{v}(t-1)+0.0018\hat{v}(t-2)$. Next, for NFN identification, we set parameters $\rho=1.0$ and $\lambda=0.01$. Thus, the NFN parameters can be identified by using the proposed scheme.

The identified NFN-based Hammerstein system is employed for concentration control for CSTR. The design principle of the control system is similar to that of the pH neutralization process. Currently, the controller parameters with $K=0.15$ and $\tau=0.6$ are chosen, and the sampling time and prediction step size of the MPC controller are 0.02 s and 5, respectively. To verify the performance of the proposed control system, the traditional PI controller, the Control-H-F-FFSG method, and the MPC-H method are used for comparison, and the control results of the concentration and inlet flow rate using different methods are illustrated in Fig. 8.




Fig. 8 Results of setting value 0.1

According to Fig. 8, when the set point is 0.1, the set value is obtained at a high speed and with a short adjustment time by applying the designed controller based on the estimated NFN-Hammerstein systems. In contrast, the traditional PI controller, MPC-H method, and Control-H-F-FFSG method need more time to reach the set value. In terms of adjustment time, the proposed method has a noticeable reduction compared with the MPC-H method, Control-H-F-FFSG method, and traditional PI controller, which further proves the validity of the proposed control scheme.

5 Conclusions

In this paper, we propose an identification strategy for Hammerstein nonlinear systems for industrial application by applying data filtering and a recursive approach. The two main advantages of the presented scheme are: (1) leveraging the step signals' trait of not stimulating the nonlinear characteristic, the parameters of both linear and nonlinear blocks are independently identified using hybrid signals; (2) a data filtering technology is used for Hammerstein system identification, therefore reducing the impact of measurement noises and improving identification accuracy. In our future work, two aspects will be addressed. On one hand, for the Hammerstein system with colored measurement noise interference, we will improve the identification accuracy by estimating the variance of the noise. On the other hand, we will expand the application scope of the proposed method to control more nonlinear systems, such as power grid systems (Yang et al., 2021; Huang G et al., 2022) and permanent magnet synchronous motors (Xiao et al., 2022).

Contributors

Mingguang ZHANG and Feng LI designed the research and drafted the paper. Mingguang ZHANG, Feng LI, Yang YU, and Qingfeng CAO revised and finalized the paper.

Compliance with ethics guidelines

Mingguang ZHANG, Feng LI, Yang YU, and Qingfeng CAO declare that they have no conflict of interest.

Data availability

The data that support the findings of this study are available from the corresponding author upon reasonable request.

References

- Chen XM, Chen HF, 2011. Recursive identification for MIMO Hammerstein systems. *IEEE Trans Autom Contr*, 56(4): 895-902. <https://doi.org/10.1109/TAC.2010.2101691>
- Cui MY, Liu HF, Li ZH, et al., 2014. Identification of Hammerstein model using functional link artificial neural network. *Neurocomputing*, 142:419-428. <https://doi.org/10.1016/j.neucom.2014.03.051>
- Ding F, Wang YJ, Ding J, 2015. Recursive least squares parameter identification algorithms for systems with colored noise using the filtering technique and the auxiliary model. *Dig Signal Process*, 37:100-108. <https://doi.org/10.1016/j.dsp.2014.10.005>
- Du JJ, Zhang L, Han QB, 2018. A novel weighting method for multi-linear MPC control of Hammerstein systems based

- on included angle. *ISA Trans*, 80:212-220.
<https://doi.org/10.1016/j.isatra.2018.06.008>
- Filipovic V, 2019. Recursive identification of block-oriented nonlinear systems in the presence of outliers. *J Process Contr*, 78:1-12. <https://doi.org/10.1016/j.jprocont.2019.03.015>
- Ge XH, Xiao SY, Han QL, et al., 2022. Dynamic event-triggered scheduling and platooning control co-design for automated vehicles over vehicular ad-hoc networks. *IEEE/CAA J Autom Sin*, 9(1):31-46. <https://doi.org/10.1109/JAS.2021.1004060>
- Ge XH, Han QL, Wu Q, et al., 2023. Resilient and safe platooning control of connected automated vehicles against intermittent denial-of-service attacks. *IEEE/CAA J Autom Sin*, 10(5):1234-1251.
<https://doi.org/10.1109/JAS.2022.105845>
- Hammar K, Djama T, Bettayeb M, 2019. Identification of fractional Hammerstein system with application to a heating process. *Nonl Dynam*, 96(4):2613-2626.
<https://doi.org/10.1007/s11071-019-04946-2>
- Hou J, Su H, Yu CP, et al., 2023. Bias-correction errors-in-variables Hammerstein model identification. *IEEE Trans Ind Electron*, 70(7):7268-7279.
<https://doi.org/10.1109/TIE.2022.3199931>
- Huang G, Wu F, Guo CX, 2022. Smart grid dispatch powered by deep learning: a survey. *Front Inform Technol Electron Eng*, 23(5):763-776.
<https://doi.org/10.1631/FITEE.2000719>
- Huang J, Mo ZB, Zhang ZY, et al., 2022. Behavioral control task supervisor with memory based on reinforcement learning for human–multi-robot coordination systems. *Front Inform Technol Electron Eng*, 23(8):1174-1188.
<https://doi.org/10.1631/FITEE.2100280>
- Janjanam L, Saha SK, Kar R, 2023. Optimal design of Hammerstein cubic spline filter for nonlinear system modeling based on snake optimizer. *IEEE Trans Ind Electron*, 70(8):8457-8467. <https://doi.org/10.1109/TIE.2022.3213886>
- Ji Y, Kang Z, Liu XM, 2021. The data filtering based multiple-stage Levenberg–Marquardt algorithm for Hammerstein nonlinear systems. *Int J Robust Nonl Contr*, 31(15):7007-7025. <https://doi.org/10.1002/rnc.5675>
- Jia L, Chiu MS, Ge SS, 2005. A noniterative neuro-fuzzy based identification method for Hammerstein processes. *J Process Contr*, 15(7):749-761.
<https://doi.org/10.1016/j.jprocont.2005.03.006>
- Khalifa TR, El-Nagar AM, El-Brawany MA, et al., 2021. A novel Hammerstein model for nonlinear networked systems based on an interval type-2 fuzzy Takagi–Sugeno–Kang system. *IEEE Trans Fuzzy Syst*, 29(2):275-285.
<https://doi.org/10.1109/TFUZZ.2020.3007460>
- Kothari K, Mehta U, Prasad V, et al., 2020. Identification scheme for fractional Hammerstein models with the delayed Haar wavelet. *IEEE/CAA J Autom Sin*, 7(3):882-891.
<https://doi.org/10.1109/JAS.2020.1003093>
- Li F, Zheng T, He NB, et al., 2022. Data-driven hybrid neural fuzzy network and ARX modeling approach to practical industrial process identification. *IEEE/CAA J Autom Sin*, 9(9):1702-1705.
<https://doi.org/10.1109/JAS.2022.105821>
- Li F, Liang MJ, Luo YS, 2023a. Correlation analysis-based parameter learning of Hammerstein nonlinear systems with output noise. *Eur J Contr*, 72:100819.
<https://doi.org/10.1016/j.ejcon.2023.100819>
- Li F, Zheng T, Cao QF, 2023b. Modeling and identification for practical nonlinear process using neural fuzzy network-based Hammerstein system. *Trans Inst Meas Contr*, 45(11):2091-2102. <https://doi.org/10.1177/01423312221143777>
- Li F, Zhu XJ, He NB, et al., 2023c. Parameter learning for the nonlinear system described by Hammerstein model with output disturbance. *Asian J Contr*, 25(2):886-898.
<https://doi.org/10.1002/asjc.2829>
- Ma JX, Xiong WL, Ding F, et al., 2016. Data filtering based forgetting factor stochastic gradient algorithm for Hammerstein systems with saturation and preload nonlinearities. *J Franklin Inst*, 353(16):4280-4299.
<https://doi.org/10.1016/j.jfranklin.2016.07.025>
- Ma JX, Huang B, Ding F, 2020. Iterative identification of Hammerstein parameter varying systems with parameter uncertainties based on the variational Bayesian approach. *IEEE Trans Syst Man Cybern Syst*, 50(3):1035-1045.
<https://doi.org/10.1109/TSMC.2017.2756913>
- Ma L, Liu XG, 2016. Recursive maximum likelihood method for the identification of Hammerstein ARMAX system. *Appl Math Model*, 40(13-14):6523-6535.
<https://doi.org/10.1016/j.apm.2016.01.062>
- Michalkiewicz J, 2012. Modified Kolmogorov’s neural network in the identification of Hammerstein and Wiener systems. *IEEE Trans Neur Netw Learn Syst*, 23(4):657-662.
<https://doi.org/10.1109/TNNLS.2011.2178322>
- Ning BD, Han QL, Zuo ZY, et al., 2023. Fixed-time and prescribed-time consensus control of multiagent systems and its applications: a survey of recent trends and methodologies. *IEEE Trans Ind Inform*, 19(2):1121-1135.
<https://doi.org/10.1109/TII.2022.3201589>
- Shi ZW, Yang HD, Dai M, 2023. The data-filtering based bias compensation recursive least squares identification for multi-input single-output systems with colored noises. *J Franklin Inst*, 360(7):4753-4783.
<https://doi.org/10.1016/j.jfranklin.2023.01.040>
- Smith JG, Kamat S, Madhavan KP, 2007. Modeling of pH process using wavenet based Hammerstein model. *J Process Contr*, 18(6):551-561.
<https://doi.org/10.1016/j.jprocont.2006.11.001>
- Wang DQ, Ding F, Chu YY, 2013. Data filtering based recursive least squares algorithm for Hammerstein systems using the key-term separation principle. *Inform Sci*, 222:203-212.
<https://doi.org/10.1016/j.ins.2012.07.064>
- Wang DQ, Zhang S, Gan M, et al., 2020. A novel EM identification method for Hammerstein systems with missing output data. *IEEE Trans Ind Inform*, 16(4):2500-2508.
<https://doi.org/10.1109/TII.2019.2931792>
- Wang YJ, Yang L, 2021. An efficient recursive identification algorithm for multilinear systems based on tensor decomposition. *Int J Robust Nonl Contr*, 31(16):7920-7936.
<https://doi.org/10.1002/rnc.5718>
- Wen GH, Yu XH, Liu ZW, 2021. Recent progress on the study of distributed economic dispatch in smart grid: an overview.

- Front Inform Technol Electron Eng*, 22(1):25-39.
<https://doi.org/10.1631/FITEE.2000205>
- Xiao LF, Ma LM, Huang XH, 2022. Intelligent fractional-order integral sliding mode control for PMSM based on an improved cascade observer. *Front Inform Technol Electron Eng*, 23(2):328-338.
<https://doi.org/10.1631/FITEE.2000317>
- Xie ML, Ding DR, Ge XH, et al., 2023. Distributed platooning control of automated vehicles subject to replay attacks based on proportional integral observers. *IEEE/CAA J Autom Sin*, early access. <https://doi.org/10.1109/JAS.2022.105941>
- Xu L, 2016. The damping iterative parameter identification method for dynamical systems based on the sine signal measurement. *Signal Process*, 120:660-667.
<https://doi.org/10.1016/j.sigpro.2015.10.009>
- Xu L, Chen L, Xiong WL, 2015. Parameter estimation and controller design for dynamic systems from the step responses based on the newton iteration. *Nonl Dynam*, 79(3): 2155-2163. <https://doi.org/10.1007/s11071-014-1801-7>
- Yang FS, Liang XH, Guan XH, 2021. Resilient distributed economic dispatch of a cyber-power system under DoS attack. *Front Inform Technol Electron Eng*, 22(1):40-50.
<https://doi.org/10.1631/FITEE.2000201>
- Zhang H, Shi Y, Wang JM, et al., 2018. A new delay-compensation scheme for networked control systems in controller area networks. *IEEE Trans Ind Electron*, 65(9):7239-7247.
<https://doi.org/10.1109/TIE.2018.2795574>
- Zhang HY, Meng DY, Wang J, et al., 2021. Indirect adaptive fuzzy-regulated optimal control for unknown continuous-time nonlinear systems. *Front Inform Technol Electron Eng*, 22(2):155-169. <https://doi.org/10.1631/FITEE.1900610>
- Zhang XM, Han QL, Ge XH, et al., 2023. Sampled-data control systems with non-uniform sampling: a survey of methods and trends. *Annu Rev Contr*, 55:70-91.
<https://doi.org/10.1016/j.arcontrol.2023.03.004>
- Zhao WX, Weyer E, Yin G, et al., 2023. Adaptive regulation of block-oriented nonlinear systems using binary sensors with applications to automotive engine control. *IEEE Trans Autom Contr*, 68(3):1369-1382.
<https://doi.org/10.1109/TAC.2022.3151217>